



RAJKOT MUNICIPAL CORPORATION



Fire And Emergency Services

Dr. Ambedkar Bhavan, Dhebar Road, Rajkot - 360 001. Phone. No.2227222.

RMC/RFES/School Building/NOC/933/2021.

Date. .02.2021.

--- FIRE NO OBJECTION CERTIFICATE ---

Ref. No.1.R.M.C.F.B.E.NO.NOC.1088, DATE:-12.02.2021.

16-3-21


This to Fire No Objection Certificate That With Reference to Above Application of For Society of the Servants of Holy Spirit Trustee/Principal, "NIRMALA CONVENT SCHOOL - RAJKOT", (New Building), Type of Building:-Frame Structure, Use of Building:-School Building, Location:-Dr. Hedgewar Road, Nirmala Con. School Main Road, Rajkot - 360 007.(Gujarat). Rev.Sr.No.459/P, Final Plot No.424, T.P.S.No. 1 (Rajkot), O.P.No.31, Ward No.8, Floor:-G.F.+ 3rd Floor, Stair Room, Plot Area = 24213.20 sq.mt. The School Building Site Was Inspected by RMC Fire Brigade Fire Station Officers and The Documents Submitted Were Checked and Found Correct on Date:-17.02.2021.

• During inspection of the said premises following system were found adequate and in working condition.


- (1)Fire Hydrant System with Hose Box, Hose Pipe with Nozzle & Hose Reel in Working Condition each floor.
- (2)ABC Fire Extinguishers 6 kg Capacity each floor.
- (3)CO2 Fire Extinguishers 4.5 kg Capacity each floor.
- (4)Fire Pump ON/OFF Switch each floor.
- (5)Emergency Fire Alarm System each floor.
- (6)Two way fire Service inlet 2 way.

• You are hereby advised to maintain the above system in good working condition.

- (1)The Fire Fighting System to be Maintain perfect working condition all the time.
- (2)In Case of Emergency Fire Safety System must be operated by your trained person immediately.
- (3)The Fire Department of RMC will not be responsible for any loss of life & property Due to Fire/Emergency incident of your premises.
- (4) Electric Wiring must be proper and that Not be Loose and Taped in School Building Area.
- (5) Fire Water Tank for fire fighting in Above area.
- (6)Trained man power shall be available for Fire fighting premises round the clock.
- (7)Our fire Certificate is limited to Fire Fighting System available in your premises Only.
- (8) Any other instructions given by fire Department from time to time about fire Safety of the premises to be followed.
- (9)The duration of the Fire N.O.C. is valid up to One Year from the Date of Issue.


Dy. Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation




Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation